

APPLICATION CONTINUED

PART B TO BE COMPLETED BY A REGISTERED ENGINEER OR LAND SURVEYOR

() A Construction Plan which includes the required information as set forth by Chapter 420-3-1 of the Rules Governing Onsite Sewage Disposal Systems and Subdivisions is attached. The construction plan shall be certified by an engineer or land surveyor. Construction plans for alternative systems shall be certified by an engineer. Note: A construction plan is not required for a single family dwelling or a business generating 500 gallons or less of sewage a day proposing to use a conventional onsite sewage disposal system. Please refer to appropriate sections of the rules.

PART C TO BE COMPLETED BY A REGISTERED ENGINEER OR LAND SURVEYOR OR SOIL CLASSIFIER

NOTE: All percolation and soil boring results must be reported whether they passed or not.

1. Percolation Test Data (Attach Additional Sheets As Needed)

Engineer Simulated Wet Season Testing <input type="checkbox"/> No <input type="checkbox"/> Yes	Percolation Hole No.	Uniform Diameter of Hole in Inches	Total Depth of Hole	Date of Saturation	Date of Percolation Test	Stabilized Percolation Rate in Minutes per Inch
	1	10"	30"	07/21/05	07/21/05	36 MPI

2. Soil Boring Data (Attach Additional Sheets As Needed)

Boring or Pit No.	Total Depth of Boring or Pit	Date & Time of Boring or Pit	Thickness of Each Soil Layer (Starting at Ground Surface)	Character of Each Soil Layer (Color, Texture, Gray or Olive Mottling, etc.) Use Munsell Color Charts	Depth to Groundwater or Saturated Soils	Depth to Groundwater after 24 hours	Depth to Rock or Refusal Layer
1	48"	07/21	0-4"	2.5 YR 4/6 Red SANDY CLAY	NONE	NONE	NONE
			4-9"	7.5 YR 7/2 DARK BR. SANDY LOAM	NONE	NONE	NONE
			9-17"	7.5 YR 4/6 STRAWY BR. SANDY CLAY	NONE	NONE	NONE
			17-48"	5 YR 4/6 Yellowish Red SANDY CLAY	NONE	NONE	NONE

I, B. Shawn Gray, a (professional engineer), (professional surveyor), (professional soil classifier)
Print/Type Name

do hereby certify that the above and/or attached soil tests were conducted as specified in the Rules Governing Onsite Sewage Disposal and Subdivisions, Chapter 420-3-1, and are true and accurate as presented.

Signature B. Shawn Gray Date 07/24/05 Registration No. 25217
Address #6 1st STREET City Lanett State AL Zip 36863 Phone 642-4729

NOTE: This is an application **ONLY**. Completion **does not** constitute an approval or permit to install or approval for use